ITS TESTING LABORATORY PRIVATE LIMITED

Laboratory: A-114, Sector-80, Phase-II Noida, Gautam Budh Nagar - 201305, (U.P.)
(An ISO 9001: 2015, ISO 14001:2015 & ISO 45001:2018 Certified Laboratory)
Website: www.itslab.in, Email: itlrclab@gmail.com, info@itslab.in, contact@itslab.in
+91 9911659800, 9305780312, 09958849764

TC-11181

TEST REPORT

Test Report of	Report Code	Date of Issue
Ambient Noise	N-130326-27	20/03/2026

Issued To : MS LALITPUR POWER GENERATION COMPANY LIMITED
VILLAGE- MIRCHWARA AND BUROGAON, TEHSIL- MAHRONI, LALITPUR-284123 (U.P) INDIA

SAMPLING & ANALYSIS DATA

Sample Drawn On : 11/03/2026
Sample Drawn By : Mr. R .K. Singh (ITS)
Sample Received On : 13/03/2026
Sample description : Ambient Noise
Sampling Location : Near-Admin Building
Analysis Duration : 13/03/2026 to 20/03/2026

1	2	3	4	5	6	7	8	9	10
65.2	63.4	62.9	66.2	63.8	60.9	64.9	63.8	62.8	55.3

Test Parameters	Results	Units	Requirement (as per CPCB Guidelines Limits in dB (A) Leq	
Maximum Sound Level	66.2	dB(A)	Category of Area/ Zone	Day Time
Minimum Sound Level	55.3	dB(A)	Industrial Area	75
Average Value	62.9	dB(A	Residential Area	55
			Commercial Area	65
			Silence Zone	50

CHECKED BY

ITS TESTING LABORATORY PVT. LTD.

AUTHORIZED SIGNATORY

Terms & Conditions :
1. Test reports are valid only for the samples tested in our laboratory. 2. Samples will destroyed as per quality policy.
3. Any complaints about the report should be communicated in writing within 7 days.
4. Total liability or our laboratory is limited to invoiced amount.

ITS TESTING LABORATORY PRIVATE LIMITED

Laboratory: A-114, Sector-80, Phase-II Noida, Gautam Budh Nagar - 201305, (U.P.)
(An ISO 9001: 2015, ISO 14001:2015 & ISO 45001:2018 Certified Laboratory)
Website: www.itslab.in, Email: itlrclab@gmail.com, info@itslab.in, contact@itslab.in
+91 9911659800, 9305780312, 09958849764

TC-11181

TEST REPORT

Test Report of	Report Code	Date of Issue
Ambient Noise	N-130326-26	20/03/2026

Issued To : MS LALITPUR POWER GENERATION COMPANY LIMITED
VILLAGE- MIRCHWARA AND BUROGAON, TEHSIL- MAHRONI, LALITPUR-284123 (U.P) INDIA

SAMPLING & ANALYSIS DATA

Sample Drawn On	:	11/03/2026
Sample Drawn By	:	Mr. R .K. Singh (ITS)
Sample Received On	:	13/03/2026
Sample description	:	Ambient Noise
Sampling Location	:	Main Gate No-1 Near-Switch Yard
Analysis Duration	:	13/03/2026 to 20/03/2026

1	2	3	4	5	6	7	8	9	10
51.5	49.2	53.9	48.9	44.2	47.9	46.2	46.8	42.2	48.2

Test Parameters	Results	Units	Requirement (as per CPCB Guidelines Limits in dB (A) Leq	
Maximum Sound Level	53.9	dB(A)	Category of Area/ Zone	Day Time
Minimum Sound Level	42.2	dB(A)	Industrial Area	75
Average Value	47.9	dB(A	Residential Area	55
			Commercial Area	65
			Silence Zone	50

CHECKED BY

ITS TESTING LABORATORY PVT. LTD.

AUTHORIZED SIGNATORY

Terms & Conditions :
1. Test reports are valid only for the samples tested in our laboratory. 2. Samples will destroyed as per quality policy.
3. Any complaints about the report should be communicated in writing within 7 days.
4. Total liability or our laboratory is limited to invoiced amount.

ITS TESTING LABORATORY PRIVATE LIMITED

Laboratory: A-114, Sector-80, Phase-II Noida, Gautam Budh Nagar - 201305, (U.P.)
(An ISO 9001: 2015, ISO 14001:2015 & ISO 45001:2018 Certified Laboratory)
Website: www.itslab.in, Email: itlrclab@gmail.com, info@itslab.in, contact@itslab.in
+91 9911659800, 9305780312, 09958849764

TC-11181

TEST REPORT

Test Report of	Report Code	Date of Issue
Ambient Noise	N-130326-25	20/03/2026

Issued To : MS LALITPUR POWER GENERATION COMPANY LIMITED
VILLAGE- MIRCHWARA AND BUROGAON, TEHSIL- MAHRONI, LALITPUR-284123 (U.P) INDIA

SAMPLING & ANALYSIS DATA

Sample Drawn On	:	11/03/2026
Sample Drawn By	:	Mr. R .K. Singh (ITS)
Sample Received On	:	13/03/2026
Sampling Location	:	Near-D M Plant
Analysis Duration	:	13/03/2026 to 20/03/2026

1	2	3	4	5	6	7	8	9	10
52.7	51.7	54.9	51.2	52.9	52.4	51.8	50.5	56.2	52.1

Test Parameters	Results	Units	Requirement (as per CPCB Guidelines Limits in dB (A) Leq	
Maximum Sound Level	56.2	dB(A)	Category of Area/ Zone	Day Time
Minimum Sound Level	50.5	dB(A)	Industrial Area	75
Average Value	52.6	dB(A	Residential Area	55
			Commercial Area	65
			Silence Zone	50

CHECKED BY

AUTHORIZED SIGNATORY

IT TESTING LABORATORY PVT. LTD.

Terms & Conditions :
1. Test reports are valid only for the samples tested in our laboratory. 2. Samples will destroyed as per quality policy.
3. Any complaints about the report should be communicated in writing within 7 days.
4. Total liability or our laboratory is limited to invoiced amount.

ITS TESTING LABORATORY PRIVATE LIMITED

Laboratory: A-114, Sector-80, Phase-II Noida, Gautam Budh Nagar - 201305, (U.P.)
(An ISO 9001: 2015, ISO 14001:2015 & ISO 45001:2018 Certified Laboratory)
Website: www.itslab.in, Email: itlrclab@gmail.com, info@itslab.in, contact@itslab.in
+91 9911659800, 9305780312, 09958849764

TC-11181

TEST REPORT

Test Report of	Report Code	Date of Issue
Ambient Noise	N-130326-24	20/03/2026

Issued To : MS LALITPUR POWER GENERATION COMPANY LIMITED
VILLAGE- MIRCHWARA AND BUROGAON, TEHSIL- MAHRONI, LALITPUR-284123 (U.P) INDIA

SAMPLING & ANALYSIS DATA

Sample Drawn On	:	11/03/2026
Sample Drawn By	:	Mr. R .K. Singh (ITS)
Sample Received On	:	13/03/2026
Sample description	:	Ambient Noise
Sampling Location	:	Near-Ash Silo
Analysis Duration	:	13/03/2026 to 20/03/2026

1	2	3	4	5	6	7	8	9	10
63.8	63.5	61.3	64.9	66.2	63.7	65.2	68.4	61.8	72.6

Test Parameters	Results	Units	Requirement (as per CPCB Guidelines Limits in dB (A) Leq	
			Category of Area/ Zone	Day Time
Maximum Sound Level	72.6	dB(A)		
Minimum Sound Level	61.3	dB(A)	Industrial Area	75
Average Value	65.1	dB(A	Residential Area	55
			Commercial Area	65
			Silence Zone	50

CHECKED BY

AUTHORIZED SIGNATORY

ITS TESTING LABORATORY PVT. LTD.

Terms & Conditions :
1. Test reports are valid only for the samples tested in our laboratory. 2. Samples will destroyed as per quality policy.
3. Any complaints about the report should be communicated in writing within 7 days.
4. Total liability or our laboratory is limited to invoiced amount.

ITS TESTING LABORATORY PRIVATE LIMITED

Laboratory: A-114, Sector-80, Phase-II Noida, Gautam Budh Nagar - 201305, (U.P.)
(An ISO 9001: 2015, ISO 14001:2015 & ISO 45001:2018 Certified Laboratory)
Website: www.itslab.in, Email: itlrclab@gmail.com, info@itslab.in, contact@itslab.in
+91 9911659800, 9305780312, 09958849764

TC-11181

TEST REPORT

Test Report	Report Code	Date of Issue
Ambient Noise	N-130326-23	20/03/2026

Issued To : MS LALITPUR POWER GENERATION COMPANY LIMITED
VILLAGE- MIRCHWARA AND BUROGAON, TEHSIL- MAHRONI, LALITPUR-284123 (U.P) INDIA

SAMPLING & ANALYSIS DATA

Sample Drawn On	:	11/03/2026
Sample Drawn By	:	Mr. R .K. Singh (ITS)
Sample Received On	:	13/03/2026
Sample description	:	Ambient Noise
Sampling Location	:	Coal Crusher
Analysis Duration	:	13/03/2026to 20/03/2026

1	2	3	4	5	6	7	8	9	10
63.8	63.6	68.5	66.0	64.8	66.4	63.8	66.1	64.3	60.1

Test Parameters	Results	Units	Requirement (as per CPCB Guidelines Limits in dB (A) Leq	
Maximum Sound Level	68.5	dB(A)	Category of Area/ Zone	Day Time
Minimum Sound Level	63.6	dB(A)	Industrial Area	75
Average Value	64.7	dB(A	Residential Area	55
			Commercial Area	65
			Silence Zone	50

CHECKED BY

AUTHORIZED SIGNATORY

Terms & Conditions :
1. Test reports are valid only for the samples tested in our laboratory. 2. Samples will destroyed as per quality policy.
3. Any complaints about the report should be communicated in writing within 7 days.
4. Total liability or our laboratory is limited to invoiced amount.

ITS TESTING LABORATORY PRIVATE LIMITED

Laboratory: A-114, Sector-80, Phase-II Noida, Gautam Budh Nagar - 201305, (U.P.)
(An ISO 9001: 2015, ISO 14001:2015 & ISO 45001:2018 Certified Laboratory)
Website: www.itslab.in, Email: itlrclab@gmail.com, info@itslab.in, contact@itslab.in
+91 9911659800, 9305780312, 09958849764

TC-11181

TEST REPORT

Test Report of	Report Code	Date of Issue
Ambient Noise	N-130326-22	20/03/2026

Issued To : MS LALITPUR POWER GENERATION COMPANY LIMITED
VILLAGE- MIRCHWARA AND BUROGAON, TEHSIL- MAHRONI, LALITPUR-284123 (U.P) INDIA

SAMPLING & ANALYSIS DATA

Sample Drawn On	:	11/03/2026
Sample Drawn By	:	Mr. R .K. Singh (ITS)
Sample Received On	:	13/03/2026
Sample description	:	Ambient Noise
Sampling Location	:	Material Gate (Gate No-2)
Analysis Duration	:	13/03/2026 to 20/03/2026

1	2	3	4	5	6	7	8	9	10
56.8	52.0	55.9	55.2	53.3	50.5	55.8	57.3	61.8	55.7

Test Parameters	Results	Units	Requirement (as per CPCB Guidelines Limits in dB (A) Leq	
Maximum Sound Level	61.8	dB(A)	Category of Area/ Zone	Day Time
Minimum Sound Level	50.5	dB(A)	Industrial Area	75
Average Value	55.4	dB(A	Residential Area	55
			Commercial Area	65
			Silence Zone	50

CHECKED BY

ITS TESTING LABORATORY PVT. LTD.

AUTHORIZED SIGNATORY

Terms & Conditions :
1. Test reports are valid only for the samples tested in our laboratory. 2. Samples will destroyed as per quality policy.
3. Any complaints about the report should be communicated in writing within 7 days.
4. Total liability or our laboratory is limited to invoiced amount.

ITS TESTING LABORATORY PRIVATE LIMITED

Laboratory: A-114, Sector-80, Phase-II Noida, Gautam Budh Nagar - 201305, (U.P.)
(An ISO 9001: 2015, ISO 14001:2015 & ISO 45001:2018 Certified Laboratory)
Website: www.itslab.in, Email: itlrclab@gmail.com, info@itslab.in, contact@itslab.in
+91 9911659800, 9305780312, 09958849764

TC-11181

TEST REPORT

Test Report of	Report Code	Date of Issue
Ambient Noise	N-130326-21	20/03/2026

Issued To : MS LALITPUR POWER GENERATION COMPANY LIMITED
VILLAGE- MIRCHWARA AND BUROGAON, TEHSIL- MAHRONI, LALITPUR-284123 (U.P) INDIA

SAMPLING & ANALYSIS DATA

Sample Drawn On : 11/03/2026
Sample Drawn By : Mr. R .K. Singh (ITS)
Sample Received On : 13/03/2026
Sample description : Ambient Noise
Sampling Location : Walkway between Boiler & ESP
Analysis Duration : 13/03/2026 to 20/03/2026

1	2	3	4	5	6	7	8	9	10
65.9	64.0	68.2	70.7	71.9	71.1	73.7	72.5	70.8	74.4

Test Parameters	Results	Units	Requirement (as per CPCB Guidelines Limits in dB (A) Leq	
Maximum Sound Level	74.4	dB(A)	Category of Area/ Zone	Day Time
Minimum Sound Level	64.0	dB(A)	Industrial Area	75
Average Value	70.3	dB(A	Residential Area	55
			Commercial Area	65
			Silence Zone	50

CHECKED BY

ITS TESTING LABORATORY PVT. LTD.

AUTHORIZED SIGNATORY

Terms & Conditions :
1. Test reports are valid only for the samples tested in our laboratory. 2. Samples will destroyed as per quality policy.
3. Any complaints about the report should be communicated in writing within 7 days.
4. Total liability or our laboratory is limited to invoiced amount.

ITS TESTING LABORATORY PRIVATE LIMITED

Laboratory: A-114, Sector-80, Phase-II Noida, Gautam Budh Nagar - 201305, (U.P.)
(An ISO 9001: 2015, ISO 14001:2015 & ISO 45001:2018 Certified Laboratory)
Website: www.itslab.in, Email: itlrclab@gmail.com, info@itslab.in, contact@itslab.in
+91 9911659800, 9305780312, 09958849764

TC-11181

TEST REPORT

Test Report of	Report Code	Date of Issue
Ambient Noise	N-130326-20	20/03/2026

Issued To: MS LALITPUR POWER GENERATION COMPANY LIMITED
VILLAGE- MIRCHWARA AND BUROGAON, TEHSIL- MAHRONI, LALITPUR-284123 (U.P) INDIA

SAMPLING & ANALYSIS DATA

Sample Drawn On : 11/03/2026
Sample Drawn By : Mr. R .K. Singh (ITS)
Sample Received On : 13/03/2026
Sample description : Work Zone Noise
Sampling Location : Out Side T.GRoom
Analysis Duration : 13/03/2026 To 20/03/2026

1	2	3	4	5	6	7	8	9	10
71.8	70.4	74.2	73.0	74.0	77.2	73.3	75.2	77.8	73.1

Test Parameters	Results	Units	Requirement (as per CPCB Guidelines Limits in dB (A) Leq
Maximum Sound Level	77.8	dB(A)	As per Factories Act-1948 for Work zone Noise
Minimum Sound Level	70.4	dB(A)	90
Average Value	74.0	dB(A	

CHECKED BY

ITS TESTING LABORATORY PVT. LTD.

AUTHORIZED SIGNATORY

Terms & Conditions :
1. Test reports are valid only for the samples tested in our laboratory. 2. Samples will destroyed as per quality policy.
3. Any complaints about the report should be communicated in writing within 7 days.
4. Total liability or our laboratory is limited to invoiced amount.

ITS TESTING LABORATORY PRIVATE LIMITED

Laboratory: A-114, Sector-80, Phase-II Noida, Gautam Budh Nagar - 201305, (U.P.)
(An ISO 9001: 2015, ISO 14001:2015 & ISO 45001:2018 Certified Laboratory)
Website: www.itslab.in, Email: itlrclab@gmail.com, info@itslab.in, contact@itslab.in
+91 9911659800, 9305780312, 09958849764

TC-11181

TEST REPORT

Test Report of	Report Code	Date of Issue
Ambient Noise	N-130326-19	20/03/2026

Issued To: MS LALITPUR POWER GENERATION COMPANY LIMITED
VILLAGE- MIRCHWARA AND BUROGAON, TEHSIL- MAHRONI, LALITPUR-284123 (U.P) INDIA

SAMPLING & ANALYSIS DATA

Sample Drawn On : 11/03/2026
Sample Drawn By : Mr. R .K. Singh (ITS)
Sample Received On : 13/03/2026
Sample description : Work Zone Noise
Sampling Location : T. G Building 17 meter
Analysis Duration : 13/03/2026 To 20/03/2026

1	2	3	4	5	6	7	8	9	10
80.3	81.5	84.1	83.7	81.1	80.1	80.9	83.0	81.2	82.6

Test Parameters	Results	Units	
Maximum Sound Level	84.1	dB(A)	As per Factories Act-1948 for Work zone Noise
Minimum Sound Level	80.1	dB(A)	90
Average Value	81.9	dB (A	

CHECKED BY

AUTHORIZED SIGNATORY

Terms & Conditions :
1. Test reports are valid only for the samples tested in our laboratory. 2. Samples will destroyed as per quality policy.
3. Any complaints about the report should be communicated in writing within 7 days.
4. Total liability or our laboratory is limited to invoiced amount.

ITS TESTING LABORATORY PRIVATE LIMITED

Laboratory: A-114, Sector-80, Phase-II Noida, Gautam Budh Nagar - 201305, (U.P.)
(An ISO 9001: 2015, ISO 14001:2015 & ISO 45001:2018 Certified Laboratory)
Website: www.itslab.in, Email: itlrclab@gmail.com, info@itslab.in, contact@itslab.in
+91 9911659800, 9305780312, 09958849764

TC-11181

TEST REPORT

Test Report of	Report Code	Date of Issue
Ambient Noise	N-130326-18	20/03/2026

ISSUED TO: MS LALITPUR POWER GENERATION COMPANY LIMITED
VILLAGE- MIRCHWARA AND BUROGAON, TEHSIL- MAHRONI, LALITPUR-284123 (U.P) INDIA

SAMPLING & ANALYSIS DATA

Sample Drawn On : 11/03/2026
Sample Drawn By : Mr. R .K. Singh (ITS)
Sample Received On : 13/03/2026
Sample description : Ambient Noise
Sampling Location : Near-CCR Building
Analysis Duration : 13/03/2026 to 20/03/2026

1	2	3	4	5	6	7	8	9	10
55.2	60.4	63.0	62.7	56.8	54.6	62.3	54.4	52.3	60.3

Test Parameters	Results	Units	Requirement (as per CPCB Guidelines Limits in dB (A) Leq	
Maximum Sound Level	63	dB(A)	Category of Area/ Zone	Day Time
Minimum Sound Level	52.3	dB(A)	Industrial Area	75
Average Value	58.2	dB(A	Residential Area	55
			Commercial Area	65
			Silence Zone	50

CHECKED BY

AUTHORIZED SIGNATORY

ITS TESTING LABORATORY PVT. LTD.

Terms & Conditions :
1. Test reports are valid only for the samples tested in our laboratory. 2. Samples will destroyed as per quality policy.
3. Any complaints about the report should be communicated in writing within 7 days.
4. Total liability or our laboratory is limited to invoiced amount.