

(An ISO 9001:2015, 14001:2015, 45001:2018 & MOEF Approved Lab)

Lab - H1-837, Near Pollution Control Board, RIICO Industrial Area, Bhiwadi, Distt. Alwar (Rajasthan)-301019

Ph. No.: 01493-294022, 09694666022, Email: asiaenvirolab@gmail.com, Website: www.asiaenvirolab.com

Test Report of	Report Code	Date of Issue	
Boiler Stack Emission	ST-200323-09	27/03/2023	

ISSUED TO: M/S LALITPUR POWER GENERATION COMPANY LIMITED

VILLAGE-MIRCHWARA-BURÖGAON-CHIGLAUWA, BAR-BANPUR ROAD,

BLOCK BAR, LALITPUR- 284123 (U.P) INDIA

## SAMPLING & ANALYSIS DATA

17/03/2023 (15:55 to 16:25) Sample Drawn on

Mr. Vivek Kumar/Amit Kumar Sharma(Asia Sample Drawn By

Enviro Lab)

**Boiler Stack Emission** Sample Description

30 Sampling Time

Sampling Plan & Procedure SOP/SE/09 17/03/2023 TO 27/03/2023

Analysis Duration 33 Ambient Temperature(°C)

Stack Temperature (°C)

Stack Attached to Boilers No-3 Source of Emission

ESP Attached APCS Coal Type of Fuel used

309.5 ton/Hrs Quantity of Flue Used 86.95% Operating Load **RCC** Type of Stack

7.5 Diameter of Stack(meter) (at port Hole) 275 Height of Stack above ground level(meter) 21.32 Average Velocity of Flue Emission (m/s) 2710886.49 Quantity Of Emission Discharge (Nm<sup>3</sup>/hr)

	ANALYSIS TEST RESULT					
S.N.	Parameter	Test Method	Results	Units	CPCB EMISSION Standard for Boiler (Max)	
1	Particulate Matter (PM)	IS:11255(Part-1)	41.80	mg/Nm³	50	
2.	Sulphur dioxide (as SO2)	IS:11255(Part-2)	972	mg/Nm <sup>3</sup>	200	
3.	Nitrogen dioxide (as NO2)	IS:11255(Part-7)	332	mg/Nm <sup>3</sup>	450	
4.	Carbon monoxide (as CO)	IS:13270	0.0005	% by Volume	1% Volume	
5.	Mercury (as Hg)	AAS Method	BDL	mg/Nm³	0.03	

Remark-The standard limit is applicable w.e.f Dec2017 onwards as per Govt. Notification Dated 07/12/2015.

BDL-Below detection Limit

CHECKED BY

AUTHORIZE

Note: 1. The result listed refer only to the tested samples and applicable parameters.

Sample will be destroyed one month from the date of issue of test certificate.
 Any complaints about this report should be communicated within 7 days of issue of this report

4. The report is Not to be reproduced-wholly or in part and can Not be used as an evidence in the Court of law and should Not be used in any advertising Media without our special permission in writing.



(An ISO 9001:2015, 14001:2015, 45001:2018 & MOEF Approved Lab

Lab - H1-837, Near Pollution Control Board, RIICO Industrial Area, Bhiwadi, Distt. Alwar (Rajasthan)-301019

Ph. No.: 01493-294022, 09694666022, Email: asiaenvirolab@gmail.com, Website: www.asiaenvirolab.com

Test Report of	Report Code	Date of Issue
Boiler Stack Emission	ST-200323-08	27/03/2023

ISSUED TO: M/S LALITPUR POWER GENERATION COMPANY LIMITED VILLAGE-MIRCHWARA-BUROGAON-CHIGLAUWA, BAR-BANPUR ROAD, BLOCK BAR, LALITPUR- 284123 (U.P) INDIA

# **SAMPLING & ANALYSIS DATA**

17/03/2023 (15:20 to 15:50) Sample Drawn on

Mr. Vivek Kumar/ Vivek Prajapati (Asia Enviro Sample Drawn By

Lab)

**Boiler Stack Emission** Sample Description

30 Sampling Time

SOP/SE/09 Sampling Plan & Procedure

20/03/2023 TO 27/03/2023 **Analysis Duration** 

Ambient Temperature(°C) Stack Temperature (°C)

Stack Attached to Boilers No-2 Source of Emission

ESP Attached APCS Coal Type of Fuel used 308 ton/Hrs Quantity of Flue Used 76.76% Operating Load **RCC** Type of Stack 7.5 Diameter of Stack(meter) (at port Hole) 275

Height of Stack above ground level(meter) Average Velocity of Flue Emission (m/s) 21.01 2671469.29 Quantity Of Emission Discharge (Nm<sup>3</sup>/hr)

	ANALYSIS TEST RESULT					
S.N.	Parameter	Test Method	Results	Units	CPCB EMISSION Standard for Boiler (Max)	
1.	Particulate Matter (PM)	IS:11255(Part-1)	39.2	mg/Nm³	50	
2.	Sulphur dioxide (as SO2)	IS:11255(Part-2)	969	mg/Nm³	200	
3.	Nitrogen dioxide (as NO2)	IS:11255(Part-7)	329	mg/Nm³	450	
4.	Carbon monoxide (as CO)	IS:13270	0.0005	% by Volume	1% Volume	
5.	Mercury (as Hg)	AAS Method	BDL	mg/Nm³	0.03	

Remark-The standard limit is applicable w.e.f Dec2017 onwards as per Govt. Notification Dated 07/12/2015.

BDL-Below detection Limit

CHECKED BY

**AUTHORIZED'S** 

Note: 1. The result listed refer only to the tested samples and applicable parameters.

Sample will be destroyed one month from the date of issue of test certificate.
 Any complaints about this report should be communicated within 7 days of issue of this report

4. The report is Not to be reproduced-wholly or in part and can Not be used as an evidence in the Court of law and should Not be used in any advertising

Media without our special permission in writing.



(An ISO 9001:2015, 14001:2015, 45001:2018 & MOEF Approved Lab

Lab - H1-837, Near Pollution Control Board, RIICO Industrial Area, Bhiwadi, Distt. Alwar (Rajasthan)-301019

Ph. No.: 01493-294022, 09694666022, Email: asiaenvirolab@gmail.com, Website: www.asiaenvirolab.com

Test Report of	Report Code	Date of Issue
<b>Boiler Stack Emission</b>	ST-200323-07	27/03/2023

ISSUED TO: M/S LALITPUR POWER GENERATION COMPANY LIMITED VILLAGE-MIRCHWARA-BUROGAON-CHIGLAUWA, BAR-BANPUR ROAD, BLOCK BAR, LALITPUR- 284123 (U.P) INDIA

### SAMPLING & ANALYSIS DATA

17/03/2023 (Time 14:50 to 15:20) Sample Drawn on

Mr. Vivek Kumar/Amit Kumar Sharma (Asia Sample Drawn By

Enviro Lab)

**Boiler Stack Emission** Sample Description

Sampling Time

SOP/SE/09 Sampling Plan & Procedure

17/03/2023 TO 27/03/2023 **Analysis Duration** 

Ambient Temperature(°C) 32 115 Stack Temperature (°C)

Stack Attached to Boilers No-1 Source of Emission

**ESP** Attached APCS Coal Type of Fuel used 284.1 ton/Hrs Quantity of Flue Used 63.59% Operating Load

**RCC** Type of Stack 7.5 Diameter of Stack(meter) (at port Hole) 275 Height of Stack above ground level(meter) 20.86 Average Velocity of Flue Emission (m/s) 2633277.72

Quanti	ity Of Emission Discharge (N.	$m^3/hr)$ :	2633277.72	2	
		ANALYSIS TE	ST RESULT		
S.N.	Parameter	Test Method	Results	Units	CPCB EMISSION Standard for Boiler
	,				(Max)
1.	Particulate Matter (PM)	IS:11255(Part-1)	38.65	mg/Nm³	50
2.	Sulphur dioxide (as SO2)	IS:11255(Part-2)	982	mg/Nm <sup>3</sup>	200
3.	Nitrogen dioxide (as NO2)	IS:11255(Part-7)	322	mg/Nm <sup>3</sup>	450
4.	Carbon monoxide (as CO)	IS:13270	0.0006	% by Volume	1% Volume
5	Mercury (as Ha)	AAS Method	BDL	mg/Nm <sup>3</sup>	0.03

Remark-The standard limit is applicable w.e.f Dec2017 onwards as per Govt. Notification Dated 07/12/2015

BDL-Below detection Limit

CHECKED BY

AUTHORIZED

Note: 1. The result listed refer only to the tested samples and applicable parameters.

Sample will be destroyed one month from the date of issue of test certificate.
 Any complaints about this report should be communicated within 7 days of issue of this report

4. The report is Not to be reproduced-wholly or in part and can Not be used as an evidence in the Court of law and should Not be used in any advertising Media without our special permission in writing.