



ASIA ENVIRO LAB

(An ISO 9001:2015, 14001:2015, 45001:2018 & MOEF Approved Lab)

Job Description : Environmental Testing, ETP/STP Manufacturing, ETP/STP Plant Operation Pollution NDC Etc.

Lab - H1-837, Near Pollution Control Board, RIICO Industrial Area, Bhiwadi, Distt. Alwar (Rajasthan)-301019

Ph. No. : 01493-294022, 09694666022, Email : asiaenvirolab@gmail.com, Website : www.asiaenvirolab.com

TEST REPORT

Test Report of	Report Code	Date of Issue
Waste Water	WW- 200323-02	27/03/2023

Issued To: M/S LALITPUR POWER GENERATION COMPANY LIMITED
VILLAGE-MIRCHWARA-BUROGAON-CHIGLAUWA, BAR-BANPUR ROAD,
BLOCK BAR, LALITPUR- 284123 (U.P) INDIA

SAMPLING & ANALYSIS DATA

Sample Description	ETP Inlet Water
Date of Sample Drawn	19/03/2023
Sample Drawn By	Mr.Amit Kumar Sharma (Asia Enviro Lab)
Date of Sample Received	20/03/2023
Protocol Used for Sampling	APHA-23 rd edit
Analysis Duration	20/03/2023 to 27/03/2023

ANALYSIS TEST RESULTS

S.No	Parameter	Test Method	Results	Units
1.	pH	IS:3025(Part-11):1983	8.59	-
2.	Total Suspended Solid (TSS)	IS:3025(Part-17):1984	288	mg/l
3.	Chemical Oxygen Demand (as O ₂)	APHA 5220 B:2005	388	mg/l
4.	Biological Oxygen Demand (as O ₂)	IS:3025(Part-44):1993	112	mg/l
5.	Oil & grease	IS:3025(Part-39):1984	18.0	mg/l

CHECKED BY

AUTHORIZED SIGNATORY



- Note: 1. The result listed refer only to the tested samples and applicable parameters.
2. Sample will be destroyed one month from the date of issue of test certificate.
3. Any complaints about this report should be communicated within 7 days of issue of this report.
4. The report is Not to be reproduced-wholly or in part and can Not be used as an evidence in the Court of law and should Not be used in any advertising Media without our special permission in writing.



ASIA ENVIRO LAB

(An ISO 9001:2015, 14001:2015, 45001:2018 & MOEF Approved Lab)

Job Description : Environmental Testing, ETP/STP Manufacturing, ETP/STP Plant Operation Pollution NCC Etc.

Lab - H1-837, Near Pollution Control Board, RIICO Industrial Area, Bhiwadi, Distt. Alwar (Rajasthan)-301019

Ph. No. : 01493-294022, 09694666022, Email : asiaenvirolab@gmail.com, Website : www.asiaenvirolab.com

TEST REPORT

Test Report of	Report Code	Date of Issue
Waste Water	WW- 200323-01	27/03/2023

Issued To: M/S LALITPUR POWER GENERATION COMPANY LIMITED
VILLAGE-MIRCHWARA-BUROGAON-CHIGLAUWA, BAR-BANPUR ROAD,
BLOCK BAR, LALITPUR- 284123 (U.P) INDIA

Sample Description	ETP Outlet Water
Date of Sample Drawn	19/03/2023
Sample Drawn By	Mr. Amit Kumar Sharma (Asia Enviro Lab)
Date of Sample Received	20/03/2023
Protocol Used for Sampling	APHA-23 rd edit
Analysis Duration	20/03/2023 to 27/03/2023

ANALYSIS TEST RESULT

S.No	Parameter	Test Method	Results	Units	Limit as per CPCB Norms
1.	pH	IS:3025(Part-11):1983	7.32	-	5.5-9.0
2.	Total Suspended Solid	IS:3025(Part-17):1984	23.8	mg/l	100
3.	Chemical Oxygen Demand (as O ₂)	APHA 5220 B:2005	52.0	mg/l	250
4.	Biological Oxygen Demand (as O ₂)	IS:3025(Part-44):1993	11.0	mg/l	30
5.	Oil & grease	IS:3025(Part-39):1984	<1.0	mg/l	10

CHECKED BY

AUTHORIZED SIGNATORY



- Note: 1. The result listed refer only to the tested samples and applicable parameters.
2. Sample will be destroyed one month from the date of issue of test certificate.
3. Any complaints about this report should be communicated within 7 days of issue of this report.
4. The report is Not to be reproduced-wholly or in part and can Not be used as an evidence in the Court of law and should Not be used in any advertising, Media without our special permission in writing.