



Analyzing for an Assured
Future

NOIDA TESTING LABORATORIES

(A Government of India Approved Testing Laboratory)

(An ISO : 9001 : 2015, ISO 45001 : 2018 (OH&S) Certified & NABL Accredited Laboratory)

MoEF & CC (Ministry of Environment, Forest & Climate Change), UPPCB Recognized Laboratory

+91-9313611642, 8510081921, 7503031145, 8527870572, 7503031146, 9999794369

TEST CERTIFICATE

Issued To: M/s Lalitpur Power Generation
Company Limited

Address: Village- Mirchwara and Burogaon,
Tehsil- Mahroni, Lalitpur-284123 (U.P) India

Report Code : AN-280325-034
ULR No. : TC681425000002185F
Test Report of : Ambient Noise
Discipline : Atmospheric Pollution
Service Request No : NTL/SRF/03/25-02
Service Request Date : 24/03/2025
Report Issue Date : 02/04/2025

SAMPLING & ANALYSIS DATA

Sample Drawn On : 25/03/2025
Sample Drawn By : Mr. Umashankar Sharma (NTL)
Sample Received On : 28/03/2025
Sample description : Ambient Noise
Sampling Location : Near-CCR Building
Analysis Duration : 25/03/2024 to 02/04/2025

1	2	3	4	5	6	7	8	9	10
55.6	58.4	52.1	56.4	55.7	58.2	54.6	58.8	54.6	52.6
<u>Test Parameters</u>		<u>Results</u>	<u>Units</u>	<u>Requirement (as per CPCB Guidelines Limits in</u> <u>dB (A) Leq</u>					
Maximum Sound Level		58.8	dB(A)	Category of Area/ Zone	Day Time	As per Factories Act-1948 for Work zone Noise			
Minimum Sound Level		52.1	dB(A)			Industrial Area	75	85	
Average Value		55.4	dB(A)	Residential Area	55				
				Commercial Area	65				
				Silence Zone	50				

Notes:

- The results given above are related to the tested sample, as received & mentioned parameters. The customer asked for the above tests only.
- Responsibility of the Laboratory is limited to the invoiced amount only.
- This test report will not be generated again, either wholly or in part, without prior written permission of the laboratory.
- The test samples will be disposed off after two weeks from the date of issue of test report, unless until specified by the customer.



CHECKED BY

AUTHORIZED SIGNATORY

Laboratory : GT-20, Sector-117, Gautam Budh Nagar - 201 301 (U.P.)

Branch Office :

HARIDWAR | DEHRADUN | PUNE

E-mail : noida.laboratory@gmail.com | Website : www.noidalabs.com



Analyzing for an Assured
Future

NOIDA TESTING LABORATORIES

(A Government of India Approved Testing Laboratory)

(An ISO : 9001 : 2015, ISO 45001 : 2018 (OH&S) Certified & NABL Accredited Laboratory)

MoEF & CC (Ministry of Environment, Forest & Climate Change), UPPCB Recognized Laboratory

+91-9313611642, 8510081921, 7503031145, 8527870572, 7503031146, 9999794369

TEST CERTIFICATE

Issued To: M/s Lalitpur Power Generation
Company Limited

Address: Village- Mirchwara and Burogaon,
Tehsil- Mahroni, Lalitpur-284123 (U.P) India

Report Code : AN-280325-035
ULR No. : TC681425000002186F
Test Report of : Ambient Noise
Discipline : Atmospheric Pollution
Service Request No : NTL/SRF/03/25-02
Service Request Date : 24/03/2025
Report Issue Date : 02/04/2025

SAMPLING & ANALYSIS DATA

Sample Drawn On : 25/03/2025
Sample Drawn By : Mr. Umashankar Sharma (NTL).
Sample Received On : 28/03/2025
Sample description : Ambient Noise
Sampling Location : Near-T.G Inside Sample done at 17 meter
Distance from T.G
Analysis Duration : 25/03/2024 to 02/04/2025

1	2	3	4	5	6	7	8	9	10
76.4	75.2	80.5	78.2	81.5	82.6	79.6	78.8	80.2	81.4
Test Parameters		Results	Units	Requirement (as per CPCB Guidelines Limits in dB (A) Leg					
Maximum Sound Level		82.6	dB(A)	Category of Area/ Zone		Day Time	As per Factories Act- 1948 for Work zone Noise		
Minimum Sound Level		75.2	dB(A)	Industrial Area		75	85		
Average Value		78.9	dB(A)	Residential Area		55			
				Commercial Area		65			
				Silence Zone		50			

Notes:

- The results given above are related to the tested sample, as received & mentioned parameters. The customer asked for the above tests only.
- Responsibility of the Laboratory is limited to the invoiced amount only.
- This test report will not be generated again, either wholly or in part, without prior written permission of the laboratory.
- The test samples will be disposed off after two weeks from the date of issue of test report, unless until specified by the customer.



CHECKED BY

AUTHORIZED SIGNATORY

Laboratory : GT-20, Sector-117, Gautam Budh Nagar - 201 301 (U.P.)

Branch Office :

HARIDWAR | DEHRADUN | PUNE

E-mail : noida.laboratory@gmail.com | Website : www.noidalabs.com



Analyzing for an Assured
Future

NOIDA TESTING LABORATORIES

(A Government of India Approved Testing Laboratory)

(An ISO : 9001 : 2015, ISO 45001 : 2018 (OH&S) Certified & NABL Accredited Laboratory)

MoEF & CC (Ministry of Environment, Forest & Climate Change), UPPCB Recognized Laboratory

+91-9313611642, 8510081921, 7503031145, 8527870572, 7503031146, 9999794369

TEST CERTIFICATE

Issued To: M/s Lalitpur Power Generation
Company Limited

Address: Village- Mirchwara and Burogaon,
Tehsil- Mahroni, Lalitpur-284123 (U.P) India

Report Code : AN-280325-036
ULR No. : TC681425000002187F
Test Report of : Ambient Noise
Discipline : Atmospheric Pollution
Service Request No : NTL/SRF/03/25-02
Service Request Date : 24/03/2025
Report Issue Date : 02/04/2025


SAMPLING & ANALYSIS DATA

Sample Drawn On : 25/03/2025
Sample Drawn By : Mr. Umashankar Sharma (NTL)
Sample Received On : 28/03/2025
Sample description : Ambient Noise
Sampling Location : T.G. outside
Analysis Duration : 25/03/2024 to 02/04/2025

1	2	3	4	5	6	7	8	9	10
58.8	65.4	60.2	61.5	62.4	68.6	67.5	66.3	62.6	65.1
<u>Test Parameters</u>		<u>Results</u>	<u>Units</u>	<u>Requirement (as per CPCB Guidelines Limits in</u> <u>dB (A) Leq</u>					
Maximum Sound Level		68.6	dB(A)	Category of Area/ Zone		Day Time		As per Factories Act- 1948 for Work zone Noise	
Minimum Sound Level		58.8	dB(A)	Industrial Area		75		85	
Average Value		63.7	dB(A)	Residential Area		55			
				Commercial Area		65			
				Silence Zone		50			

Notes:

- The results given above are related to the tested sample, as received & mentioned parameters. The customer asked for the above tests only.
- Responsibility of the Laboratory is limited to the invoiced amount only.
- This test report will not be generated again, either wholly or in part, without prior written permission of the laboratory.
- The test samples will be disposed off after two weeks from the date of issue of test report, unless until specified by the customer.



CHECKED BY

AUTHORIZED SIGNATORY

Laboratory : GT-20, Sector-117, Gautam Budh Nagar - 201 301 (U.P.)

Branch Office :

HARIDWAR | DEHRADUN | PUNE

E-mail : noida.laboratory@gmail.com | Website : www.noidalabs.com



Analyzing for an Assured
Future

NOIDA TESTING LABORATORIES

(A Government of India Approved Testing Laboratory)

(An ISO : 9001 : 2015, ISO 45001 : 2018 (OH&S) Certified & NABL Accredited Laboratory)

MoEF & CC (Ministry of Environment, Forest & Climate Change), UPPCB Recognized Laboratory

+91-9313611642, 8510081921, 7503031145, 8527870572, 7503031146, 9999794369

TEST CERTIFICATE

Issued To: M/s Lalitpur Power Generation
Company Limited

Address: Village- Mirchwara and Burogaon,
Tehsil- Mahroni, Lalitpur-284123 (U.P) India

Report Code : AN-280325-037
ULR No. : TC681425000002188F
Test Report of : Ambient Noise
Discipline : Atmospheric Pollution
Service Request No : NTL/SRF/03/25-02
Service Request Date : 24/03/2025
Report Issue Date : 02/04/2025

SAMPLING & ANALYSIS DATA

Sample Drawn On : 25/03/2025
Sample Drawn By : Mr. Umashankar Sharma (NTL)
Sample Received On : 28/03/2025
Sample description : Ambient Noise
Sampling Location : Walkway between Boiler & ESP
Analysis Duration : 25/03/2024 to 02/04/2025

1	2	3	4	5	6	7	8	9	10
78.8	82.4	85.6	81.1	82.6	85.4	82.8	78.8	84.2	78.5
<u>Test Parameters</u>		<u>Results</u>	<u>Units</u>	<u>Requirement (as per CPCB Guidelines Limits in</u> <u>dB (A) Leg</u>					
Maximum Sound Level		85.6	dB(A)	Category of Area/ Zone	Day Time	As per Factories Act- 1948 for Work zone Noise			
Minimum Sound Level		78.5	dB(A)	Industrial Area	75	85			
Average Value		82.05	dB(A)	Residential Area	55				
				Commercial Area	65				
				Silence Zone	50				

Notes:

- The results given above are related to the tested sample, as received & mentioned parameters. The customer asked for the above tests only.
- Responsibility of the Laboratory is limited to the invoiced amount only.
- This test report will not be generated again, either wholly or in part, without prior written permission of the laboratory.
- The test samples will be disposed off after two weeks from the date of issue of test report, unless until specified by the customer.



CHECKED BY

AUTHORIZED SIGNATORY

Laboratory : GT-20, Sector-117, Gautam Budh Nagar - 201 301 (U.P.)

Branch Office :

HARIDWAR | DEHRADUN | PUNE

E-mail : noida.laboratory@gmail.com | Website : www.noidalabs.com



Analyzing for an Assured
Future

NOIDA TESTING LABORATORIES

(A Government of India Approved Testing Laboratory)

(An ISO : 9001 : 2015, ISO 45001 : 2018 (OH&S) Certified & NABL Accredited Laboratory)

MoEF & CC (Ministry of Environment, Forest & Climate Change), UPPCB Recognized Laboratory

+91-9313611642, 8510081921, 7503031145, 8527870572, 7503031146, 9999794369

TEST CERTIFICATE

Issued To: M/s Lalitpur Power Generation
Company Limited

Address: Village- Mirchwara and Burogaon,
Tehsil- Mahroni, Lalitpur-284123 (U.P) India

Report Code : AN-280325-038
ULR No. : TC681425000002189F
Test Report of : Ambient Noise
Discipline : Atmospheric Pollution
Service Request No : NTL/SRF/03/25-02
Service Request Date : 24/03/2025
Report Issue Date : 02/04/2025

SAMPLING & ANALYSIS DATA

Sample Drawn On : 25/03/2025
Sample Drawn By : Mr. Umashankar Sharma (NTL)
Sample Received On : 28/03/2025
Sample description : Ambient Noise
Sampling Location : Near-Admin Building
Analysis Duration : 25/03/2024 to 02/04/2025

1	2	3	4	5	6	7	8	9	10
52.8	51.6	59.6	54.4	57.4	52.6	57.6	59.9	58.5	56.3
<u>Test Parameters</u>		<u>Results</u>	<u>Units</u>	<u>Requirement (as per CPCB Guidelines Limits in</u> <u>dB (A) Leq</u>					
Maximum Sound Level		59.9	dB(A)	Category of Area/ Zone		Day Time		As per Factories Act- 1948 for Work zone Noise	
Minimum Sound Level		51.6	dB(A)	Industrial Area		75		85	
Average Value		55.7	dB(A)	Residential Area		55			
				Commercial Area		65			
				Silence Zone		50			

Notes:

- The results given above are related to the tested sample, as received & mentioned parameters. The customer asked for the above tests only.
- Responsibility of the Laboratory is limited to the invoiced amount only.
- This test report will not be generated again, either wholly or in part, without prior written permission of the laboratory.
- The test samples will be disposed off after two weeks from the date of issue of test report, unless until specified by the customer.



CHECKED BY

AUTHORIZED SIGNATORY

Laboratory : GT-20, Sector-117, Gautam Budh Nagar - 201 301 (U.P.)

Branch Office :

HARIDWAR | DEHRADUN | PUNE

E-mail : noida.laboratory@gmail.com | Website : www.noidalabs.com



Analyzing for an Assured
Future

NOIDA TESTING LABORATORIES

(A Government of India Approved Testing Laboratory)

(An ISO : 9001 : 2015, ISO 45001 : 2018 (OH&S) Certified & NABL Accredited Laboratory)

MoEF & CC (Ministry of Environment, Forest & Climate Change), UPPCB Recognized Laboratory

+91-9313611642, 8510081921, 7503031145, 8527870572, 7503031146, 9999794369

TEST CERTIFICATE

Issued To: M/s Lalitpur Power Generation
Company Limited

Address: Village- Mirchwara and Burogaon,
Tehsil- Mahroni, Lalitpur-284123 (U.P) India

Report Code : AN-280325-039
ULR No. : TC681425000002190F
Test Report of : Ambient Noise
Discipline : Atmospheric Pollution
Service Request No : NTL/SRF/03/25-02
Service Request Date : 24/03/2025
Report Issue Date : 02/04/2025

SAMPLING & ANALYSIS DATA

Sample Drawn On : 25/03/2025
Sample Drawn By : Mr. Umashankar Sharma (NTL)
Sample Received On : 28/03/2025
Sample description : Ambient Noise
Sampling Location : Coal Crusher Zone
Analysis Duration : 25/03/2024 to 02/04/2025

1	2	3	4	5	6	7	8	9	10
68.5	70.2	65.4	68.6	68.5	64.6	67.2	64.9	66.7	65.2
<u>Test Parameters</u>		<u>Results</u>	<u>Units</u>	<u>Requirement (as per CPCB Guidelines Limits in</u> <u>dB (A) Leg</u>					
Maximum Sound Level		70.2	dB(A)	Category of Area/ Zone	Day Time	As per Factories Act- 1948 for Work zone Noise			
Minimum Sound Level		64.6	dB(A)	Industrial Area	75	85			
Average Value		67.4	dB(A)	Residential Area	55				
				Commercial Area	65				
				Silence Zone	50				


Notes:

- The results given above are related to the tested sample, as received & mentioned parameters. The customer asked for the above tests only.
- Responsibility of the Laboratory is limited to the invoiced amount only.
- This test report will not be generated again, either wholly or in part, without prior written permission of the Laboratory.
- The test samples will be disposed off after two weeks from the date of issue of test report, unless until specified by the customer.



CHECKED BY

AUTHORIZED SIGNATORY



Laboratory : GT-20, Sector-117, Gautam Budh Nagar - 201 301 (U.P.)

Branch Office :

HARIDWAR | DEHRADUN | PUNE

E-mail : noida.laboratory@gmail.com | Website : www.noidalabs.com



Analyzing for an Assured
Future

NOIDA TESTING LABORATORIES

(A Government of India Approved Testing Laboratory)

(An ISO : 9001 : 2015, ISO 45001 : 2018 (OH&S) Certified & NABL Accredited Laboratory)

MoEF & CC (Ministry of Environment, Forest & Climate Change), UPPCB Recognized Laboratory

+91-9313611642, 8510081921, 7503031145, 8527870572, 7503031146, 9999794369

TEST CERTIFICATE

Issued To: M/s Lalitpur Power Generation
Company Limited

Address: Village- Mirchwara and Burogaon,
Tehsil- Mahroni, Lalitpur-284123 (U.P) India

Report Code : AN-280325-040
ULR No. : TC681425000002191F
Test Report of : Ambient Noise
Discipline : Atmospheric Pollution
Service Request No : NTL/SRF/03/25-02
Service Request Date : 24/03/2025
Report Issue Date : 02/04/2025

SAMPLING & ANALYSIS DATA

Sample Drawn On : 25/03/2025
Sample Drawn By : Mr. Umashankar Sharma (NTL)
Sample Received On : 28/03/2025
Sample description : Ambient Noise
Sampling Location : Near- Ash Silo
Analysis Duration : 25/03/2024 to 02/04/2025

1	2	3	4	5	6	7	8	9	10
67.5	72.5	68.9	75.1	76.6	74.2	72.6	73.5	77.2	73.1
<u>Test Parameters</u>		<u>Results</u>	<u>Units</u>	<u>Requirement (as per CPCB Guidelines Limits in</u> <u>dB (A) Leq</u>					
Maximum Sound Level		77.2	dB(A)	Category of Area/ Zone	Day Time	As per Factories Act- 1948 for Work zone Noise			
Minimum Sound Level		67.5	dB(A)	Industrial Area	75	85			
Average Value		72.3	dB(A)	Residential Area	55				
				Commercial Area	65				
				Silence Zone	50				

Notes:

- The results given above are related to the tested sample, as received & mentioned parameters. The customer asked for the above tests only.
- Responsibility of the Laboratory is limited to the invoiced amount only.
- This test report will not be generated again, either wholly or in part, without prior written permission of the laboratory.
- The test samples will be disposed off after two weeks from the date of issue of test report, unless until specified by the customer.



CHECKED BY

AUTHORIZED SIGNATORY

Laboratory : GT-20, Sector-117, Gautam Budh Nagar - 201 301 (U.P.)

Branch Office :

HARIDWAR | DEHRADUN | PUNE

E-mail : noida.laboratory@gmail.com | Website : www.noidalabs.com



Analyzing for an Assured
Future

NOIDA TESTING LABORATORIES

(A Government of India Approved Testing Laboratory)

(An ISO : 9001 : 2015, ISO 45001 : 2018 (OH&S) Certified & NABL Accredited Laboratory)

MoEF & CC (Ministry of Environment, Forest & Climate Change), UPPCB Recognized Laboratory

+91-9313611642, 8510081921, 7503031145, 8527870572, 7503031146, 9999794369

TEST CERTIFICATE

Issued To: M/s Lalitpur Power Generation
Company Limited

Address: Village- Mirchwara and Burogaon,
Tehsil- Mahroni, Lalitpur-284123 (U.P) India

Report Code : AN-280325-041
ULR No. : TC681425000002192F
Test Report of : Ambient Noise
Discipline : Atmospheric Pollution
Service Request No : NTL/SRF/03/25-02
Service Request Date : 24/03/2025
Report Issue Date : 02/04/2025

SAMPLING & ANALYSIS DATA

Sample Drawn On : 25/03/2025
Sample Drawn By : Mr. Umashankar Sharma (NTL)
Sample Received On : 28/03/2025
Sample description : Ambient Noise
Sampling Location : Near- Main Gate No - 02
Analysis Duration : 25/03/2024 to 02/04/2025

1	2	3	4	5	6	7	8	9	10
65.4	66.8	64.1	67.5	65.1	63.5	66.8	65.2	64.1	64.8
Test Parameters		Results	Units	Requirement (as per CPCB Guidelines Limits in dB (A) Leq					
Maximum Sound Level		67.5	dB(A)	Category of Area/ Zone	Day Time	As per Factories Act- 1948 for Work zone Noise			
Minimum Sound Level		63.5	dB(A)	Industrial Area	75	90			
Average Value		65.5	dB(A)	Residential Area	55				
				Commercial Area	65				
				Silence Zone	50				

Notes:

- The results given above are related to the tested sample, as received & mentioned parameters. The customer asked for the above tests only.
- Responsibility of the Laboratory is limited to the invoiced amount only.
- This test report will not be generated again, either wholly or in part, without prior written permission of the laboratory.
- The test samples will be disposed off after two weeks from the date of issue of test report, unless until specified by the customer.



CHECKED BY

AUTHORIZED SIGNATORY

Laboratory : GT-20, Sector-117, Gautam Budh Nagar - 201 301 (U.P.)

Branch Office :

HARIDWAR | DEHRADUN | PUNE

E-mail : noida.laboratory@gmail.com | Website : www.noidalabs.com



Analyzing for an Assured
Future

NOIDA TESTING LABORATORIES

(A Government of India Approved Testing Laboratory)

(An ISO : 9001 : 2015, ISO 45001 : 2018 (OH&S) Certified & NABL Accredited Laboratory)

MoEF & CC (Ministry of Environment, Forest & Climate Change), UPPCB Recognized Laboratory

+91-9313611642, 8510081921, 7503031145, 8527870572, 7503031146, 9999794369

TEST CERTIFICATE

Issued To: M/s Lalitpur Power Generation
Company Limited

Address: Village- Mirchwara and Burogaon,
Tehsil- Mahroni, Lalitpur-284123 (U.P) India

Report Code : AN-280325-042
ULR No. : TC681425000002193F
Test Report of : Ambient Noise
Discipline : Atmospheric Pollution
Service Request No : NTL/SRF/03/25-02
Service Request Date : 24/03/2025
Report Issue Date : 02/04/2025

SAMPLING & ANALYSIS DATA

Sample Drawn On : 25/03/2025
Sample Drawn By : Mr. Umashankar Sharma (NTL)
Sample Received On : 28/03/2025
Sample description : Ambient Noise
Sampling Location : Near- Main Gate No-1 Switch yard
Analysis Duration : 25/03/2024 to 02/04/2025

1	2	3	4	5	6	7	8	9	10
58.5	56.2	60.4	62.5	61.7	62.4	57.6	59.8	60.5	62.1
<u>Test Parameters</u>		<u>Results</u>	<u>Units</u>	<u>Requirement (as per CPCB Guidelines Limits in</u> <u>dB (A) Leq</u>					
Maximum Sound Level		62.5	dB(A)	Category of Area/ Zone		Day Time		As per Factories Act- 1948 for Work zone Noise	
Minimum Sound Level		56.2	dB(A)	Industrial Area		75		85	
Average Value		59.3	dB(A)	Residential Area		55			
				Commercial Area		65			
				Silence Zone		50			

Notes:

- The results given above are related to the tested sample, as received & mentioned parameters. The customer asked for the above tests only.
- Responsibility of the Laboratory is limited to the invoiced amount only.
- This test report will not be generated again, either wholly or in part, without prior written permission of the laboratory.
- The test samples will be disposed off after two weeks from the date of issue of test report, unless until specified by the customer.



CHECKED BY

AUTHORIZED SIGNATORY

Laboratory : GT-20, Sector-117, Gautam Budh Nagar - 201 301 (U.P.)

Branch Office :

HARIDWAR | DEHRADUN | PUNE

E-mail : noida.laboratory@gmail.com | Website : www.noidalabs.com



Analyzing for an Assured
Future

NOIDA TESTING LABORATORIES

(A Government of India Approved Testing Laboratory)

(An ISO : 9001 : 2015, ISO 45001 : 2018 (OH&S) Certified & NABL Accredited Laboratory)

MoEF & CC (Ministry of Environment, Forest & Climate Change), UPPCB Recognized Laboratory

+91-9313611642, 8510081921, 7503031145, 8527870572, 7503031146, 9999794369

TEST CERTIFICATE

Issued To: M/s Lalitpur Power Generation
Company Limited

Address: Village- Mirchwara and Burogaon,
Tehsil- Mahroni, Lalitpur-284123 (U.P) India

Report Code : AN-280325-043
ULR No. : TC681425000002194F
Test Report of : Ambient Noise
Discipline : Atmospheric Pollution
Service Request No : NTL/SRF/03/25-02
Service Request Date : 24/03/2025
Report Issue Date : 02/04/2025

SAMPLING & ANALYSIS DATA

Sample Drawn On : 25/03/2025
Sample Drawn By : Mr. Umashankar Sharma (NTL)
Sample Received On : 28/03/2025
Sample description : Ambient Noise
Sampling Location : Near- DM Plant
Analysis Duration : 25/03/2024 to 02/04/2025

1	2	3	4	5	6	7	8	9	10
57.4	65.8	64.2	66.8	64.5	59.2	64.7	67.1	60.8	62.1
<u>Test Parameters</u>		<u>Results</u>	<u>Units</u>	<u>Requirement (as per CPCB Guidelines Limits in dB (A) Leq</u>					
Maximum Sound Level		67.1	dB(A)	Category of Area/ Zone		Day Time		As per Factories Act-1948 for Work zone Noise	
Minimum Sound Level		57.4	dB(A)	Industrial Area		75		85	
Average Value		62.2	dB(A)	Residential Area		55			
				Commercial Area		65			
				Silence Zone		50			

Notes:

- The results given above are related to the tested sample, as received & mentioned parameters. The customer asked for the above tests only.
- Responsibility of the Laboratory is limited to the invoiced amount only.
- This test report will not be generated again, either wholly or in part, without prior written permission of the laboratory.
- The test samples will be disposed off after two weeks from the date of issue of test report, unless until specified by the customer.



CHECKED BY

AUTHORIZED SIGNATORY

Laboratory : GT-20, Sector-117, Gautam Budh Nagar - 201 301 (U.P.)

Branch Office :

HARIDWAR | DEHRADUN | PUNE

E-mail : noida.laboratory@gmail.com | Website : www.noidalabs.com